बेलौरी नगरपालिका
नगर कार्यपालिकाको कार्यालय
बेलौरी, कञ्चनपुर

प.सं.:- २०८३।०८४
च.नं.:-

सुदूरपश्चिम प्रदेश, नेपाल

दरभाउपत्र पेश गर्ने सम्बन्धी सूचना

(प्रथम पटक प्रकाशित मितिः २०८३।०८।०१)

यस नगरपालिकाको चालु आर्थिक बर्ष २०८३/०८४ को स्वीकृत बार्षिक बजेट तथा कार्यक्रम अन्तरगत सडकबत्ती सम्बन्धी सामग्री खरिद कार्यका लागि सार्वजनिक खरिद ऐन, २०६३ को दफा ४१ र सार्वजनिक खरिद नियमावली, २०६४ को नियम ८५ बमोजिम खरिद गर्नु पर्ने भएकाले यस कार्यालयमा मौजुदा सूचीमा दर्ता भएका ईच्छुक फर्म/कम्पनी/सप्लायर्सले तपसिलमा उल्लेखित मिति, समय र स्थानमा रीतपूर्वकको दरभाउपत्र पेश गर्न हुन सम्बन्धित सबैको जानकारीका लागि यो सूचना प्रकाशित गरिएको छ ।

क्र.सं.	खरिद कार्यको विवरण	लागत अनुमान (मु. अ. कर सहित)	दरभाउपत्र पेश गर्ने अन्तिम मिति, समय र स्थान	कैफियत
१.	सडकबत्ती सम्बन्धी सामग्री खरिद	८८४५३६।००	मितिः २०८३।०८।०८ समयः दिउसो १२:०० बजे स्थानः बेलौरी नगरपालिकाको. कार्यालय कञ्चनपुर	

१. दरभाउपत्र पेश गर्ने सप्लायर्स / फर्मले अनिवार्य रुपमा दरभाउपत्र पेश गर्ने व्यहोरा सम्बन्धी **लिखित निवेदन** सहित नवीकरण भएको फर्म/ कम्पनी दर्ता प्रमाणपत्रको प्रतिलिपि, नविकरण भएको व्यवसायको दर्ता प्रमाणपत्रको प्रतिलिपि, मु.अ.क. दर्ता प्रमाणपत्रको प्रतिलिपि र आ.व २०८२/०८३ को करचुक्ता प्रमाणपत्रको प्रतिलिपि वा म्याद थप स्वीकृति पत्र संलग्न गरी पेश गर्नु पर्नेछ ।

२. उक्त खरिद कार्यको लागि आवश्यक BoQ यस कार्यालयको वेबसाइट www.belaurimun.gov.np वा जिन्सी शाखा बाट उपलब्ध गर्न सकिनेछ ।

३. BoQ मा आफूले कबोल गरेको रकम अङ्क र अक्षरमा स्पष्ट बुझिने गरी लेखेर पेश गर्नु पर्नेछ । केरमेट भएको दरभाउपत्र (BoQ) र म्याद नाघी आएका दरभाउपत्र मूल्याङ्कनमा समाबेश गरिने छैन ।

४. प्रस्ताव पेश गर्ने अन्तिम दिन सार्वजनिक विदा भई कार्यालय बन्द रहेमा विदा सकिएपछि कार्यालय खुल्ला भएको दिनको कार्यालय समयभित्र प्रस्ताव पेश गर्न सकिनेछ ।

५. दरभाउ पत्र स्वीकृत वा अस्वीकृत गर्ने अधिकार कार्यालयलाई हुनेछ ।

६. पेश भएका दरभाउ पत्रहरू मिति २०८३।०८।०८ गते दिउसो २:०० बजे यस कार्यालयमा खोलिने छन ।

७. यस सूचनामा उल्लेख नभएका कुरा प्रचलित कानून बमोजिम हुनेछ । आपूर्ति र भुक्तानी सम्बन्धी थप शर्तहरू सम्झौतामा निर्धारण गरे बमोजिम हुनेछ ।

खेमराज जोशी
प्रमुख प्रशासकीय अधिकृत

बेलौरी नगरपालिका
नगर कार्यपालिकाको कार्यालय
बेलौरी, कञ्चनपुर

प.सं.:- २०८३।०८४
च.नं.:-

सुदूरपश्चिम प्रदेश, नेपाल

मिति:-२०८३।०७। १९

आयेजनाको नाम : आ. व. 2083/084 मा वडागत सडकबत्ती सामाग्री खरिद।

Bill of Quanity

सि.नं.	सामाग्रीको विवरण	स्पेसिफिकेशन	ईकाई	परिमाण	मुल्य	जम्मा मूल्य	कैफियत
१	LED Bulb	३० w	पिस	३४५			
२	होल्डर	Pendent Holder	पिस	१६०			
३	सेन्सर	१० A	पिस	१६९			
४	विजुलीको तार (कपर)	१mm	रोल	१६			
५	टेप	वाइरिङ टेप	पिस	४५			
६	बेड स्वीच	६A	पिस	७५			
७	स्ट्रीट लाइट	५०w	पिस	७९			
८	सोलार बत्तीको ब्याट्री	८२ A लिथियम	पिस	५			
९	स्ट्याण्ड	स्ट्रीट लाइटको एङ्गल	पिस	७९			

०८३/६/१९

खेमराज जोशी
प्रमुख प्रशासकीय अधिकृत

TECHNICAL SPECIFICATIONS FOR PROCUREMENT

Purpose: Minimum technical requirements for inviting quotations and purchasing. Equivalent or better quality materials may be accepted, subject to compliance with applicable Nepal Standards (NS), IEC, or other recognized standards.

S.N.	Material	Specification	Minimum technical specifications for procurement
1	LED Bulb	30 W	Rated power: 30 W; supply: 220–240 V AC, 50 Hz; LED type, energy-efficient; minimum power factor 0.9; colour temperature (3000–6500 K) as required; minimum luminous efficacy 90 lm/W; lamp base E27 unless otherwise specified; warranty at least 1 year.
2	Pendant Holder	Pendant Holder	Ceiling-suspended pendant lamp holder; E27 screw type, compatible with 30 W LED bulb; rated 250 V AC, minimum 4 A; heat-resistant, flame-retardant insulating body; copper/brass contacts; secure terminal connections and insulated cord grip; complete with mounting/ceiling rose and required accessories. For out door use purposes
3	Sensor	10 W	Electronic sensor suitable for automatic switching of the connected lighting load; 220–240 V AC, 50 Hz; rated load capacity not less than 10 W and compatible with LED lamps; adjustable time delay and sensitivity where applicable; protected enclosure suitable for intended installation; provide make, model, wiring diagram and warranty. Sensor type (photocell / other) shall be confirmed before purchase.
4	Copper Electrical Wire	1 mm (assumed 1 mm^2)	Single-core, annealed, stranded or solid copper conductor; nominal cross-sectional area 1.0 mm^2; PVC-insulated; rated voltage 450/750 V; insulation suitable for 70°C continuous operating temperature; conforming to applicable NS/IEC standard; supplied in sealed coils with manufacturer's marking, size and length. Confirm that 1 mm^2 is the intended size before ordering.
5	Insulation / Wiring Tape	Wiring Tape	Electrical-grade self-adhesive PVC insulating tape; nominal width 18–19 mm and thickness at least 0.13 mm; voltage insulation suitable for low-voltage wiring; flame-retardant, moisture-resistant and flexible; good adhesion without leaving excessive residue; black or other specified colour; supplied in rolls.
6	Bed Switch	6 A	Flush/surface mounting switch suitable for domestic lighting circuits; rated 6 A, 250 V AC, 50 Hz; single-pole, one-way unless otherwise specified; robust flame-retardant body and durable contacts; screw-type terminals; complete with plate/cover and mounting accessories; conforming to applicable NS/IEC standard.
7	Street Light	50 W	LED street-light luminaries, rated 50 W; input 220–240 V AC, 50 Hz; luminous efficiency minimum 120 lm/W; IP65 or higher ingress protection; die-cast aluminium housing with corrosion-resistant finish; tempered glass or UV-resistant lens; surge protection minimum 4 kV; power factor at least 0.9 for AC type; colour temperature 4000–6500 K; suitable heat dissipation. Supplier shall submit photometric and product data.
8	Solar Street-Light Battery	"82 AH lithium"	Rechargeable lithium battery for the proposed 50 W solar street-light system, built-in battery management system (BMS) with over-charge, over-discharge, over-current and short-circuit protection; suitable enclosure and connectors; cycle life at least 2,000 cycles at the manufacturer's stated depth of discharge; operating temperature and warranty to be stated. The source appears to state "82AH lithium"; confirm whether this means 82 Ah. Supplier must size voltage and capacity to match the luminaries, solar panel and controller and state the exact Wh/Ah rating.
9	Street-Light Stand	Street-light angle	Hot-dip-galvanized steel street-light mounting arm, designed for the offered luminaries and pole; corrosion-resistant; suitable outreach and upward angle as per site requirement; adequate wall thickness and load capacity for wind loading; complete with clamps, bolts, nuts and washers; all dimensions, material grade, thickness, outreach and angle to be submitted for approval before supply.

Important points to confirm before issuing the purchase order:

- Battery rating: clarify whether "82 lithium" means, 82 Ah,. Do not place the order until the exact voltage and capacity (Ah/Wh) are confirmed.
- Sensor: confirm the required sensor type (dusk-to-dawn photocell) and installation location.
- Copper wire: confirm that the intended size is 1.0 mm²; the source image shows "1 mm" without clearly stating the unit.
- Street-light angle : confirm pole diameter, outreach, mounting arrangement and required tilt angle based on the site.

General procurement conditions: All materials shall be new, unused and free from defects. The supplier shall provide manufacturer's datasheets, warranty documents and country of origin. The purchaser may inspect and reject non-conforming materials. Quantities shall be as stated in the approved bill of quantities/purchase order.

Kupesh Dhakal
Reg no: 2332 "A"
(NEA Belauri DCS)

Er. Lokendra Karki
Council Reg. No. 2049 "Electrical" "A" Category
(As. Engineer - Nepal Electricity Authority)