



बैजनाथ गाउँपालिका
गाउँ कार्यपालिकाको कार्यालय

रामपुर बाँके
गाउँपालिकाको कार्यालय
बाँके
२०७३



लुम्बिनी प्रदेश, नेपाल

आ.व. ०८३/०८४

सूचना नं. ०६

मिति - २०८३/०६/०६

निर्माण कार्यको प्रति इकाई बजार मूल्य पेश गर्ने सम्बन्धमा ।

प्रकाशित मिति: २०८३/०६/०६

यस बैजनाथ गाउँपालिका, गाउँ कार्यपालिकाको कार्यालयलाई आवश्यक पर्ने यसै साथ सँलग्न सूचीमा उल्लेखित स्पेशिफिकेशन भएका निर्माण कार्यको लागी लागत अनुमान तयार गर्ने प्रयोजनका लागि प्रचलित प्रति इकाई बजार मूल्य (बजार भाउ) यसै साथ सँलग्न ढाँचामा ७ (सात) दिनभित्र उपलब्ध गराइदिन हुन सम्बन्धित सबैमा अनुरोध गरिन्छ।

(Signature)
२०८३/०६/०६

कमल राज उपाध्याय

प्रमुख प्रशासकीय अधिकृत

कमल राज उपाध्याय
प्रमुख प्रशासकीय अधिकृत

बोद्धार्थ

श्री सूचना प्रविधि अधिकृतज्यू: गाउँपालिकाको Website मा प्रकाशन गर्न हुन ।

ईमेल: baijanathrumun@gmail.com / info@baijanathmun.gov.np, वेबसाइट : www.baijanathmun.gov.np

"समृद्ध बैजनाथ हाम्रो अभियान, नागरिकको मुहारमा मुस्कान"

S.No	Discription of works	Unit	Per Unit Rate (without VAT)		Remarks
			In Figure	In Words	
SHALLOW TUBE WELL					
1	Drilling of Borehole for Shallow Tube Well of 4" Dia upto required depth including all equipment, labour and casing support during Drilling. By Manual				
	HARD SOIL	Rft			
	MEDIUM SOIL	Rft			
	SOFT SOIL	Rft			
2	Drilling of Borehole for Shallow Tube Well of 4" Dia upto required depth including all equipment, labour and casing support during Drilling. By Machine				
	HARD SOIL	Rft			
	MEDIUM SOIL	Rft			
	SOFT SOIL	Rft			
3	Drilling of Borehole for Shallow Tube Well of 6" Dia upto required depth including all equipment, labour and casing support during Drilling. By Manual				
	HARD SOIL	Rft			
	MEDIUM SOIL	Rft			
	SOFT SOIL	Rft			
4	Drilling of Borehole for Shallow Tube Well of 6" Dia upto required depth including all equipment, labour and casing support during Drilling. By Machine				
	HARD SOIL	Rft			
	MEDIUM SOIL	Rft			
	SOFT SOIL	Rft			

gus



[Signature]
कमल राज उपाध्याय
प्रमुख प्रशासकीय अधिकृत

5	Construction of Shallow Tube Well (1.25 inch Dia)	Rft			
6	Screen Making Charge in MS Pipe	Rft			
7	Screen Making Charge in PVC Pipe	Rft			
8	6" MS Casing Pipe	Rft			
9	6" Casing Shoes	No			
10	6" MS Flange with Cover	No			
11	Summercial Electrical Wire 2.5 mm	Rft			
ROOFING WORK					
12	Supply, laying and fixing of Ready-made Medium Zinc Coated GI Wire Mesh having mesh opening size 60 mm × 60 mm, including rolling, cutting, weaving, assembling, placing in position, stretching, binding and all necessary materials, tools, equipment, labour and transportation, complete in all respects as per the drawings, specifications and instructions of the Site Engineer.	Sqm			
13	Supply and Fixing of UPVC Roofing Sheet with PMMA Coating and Mesh (Regular), 3 mm thick, of approved quality, UV/weather resistant, suitable for roofing applications, including necessary cutting, overlapping, fixing with approved fasteners, washers and accessories, handling, transportation, labour and all complete works as per manufacturer's specification, approved drawings and instructions of the Site Engineer.	Sqm			
14	Supply and fixing of Heritage roofing sheet, 0.50 mm thick, 120 GSM Aluminium-Zinc coated, colour coated, including cutting, overlapping, fixing with approved screws, washers and necessary accessories, complete in all respects as per manufacturer's specification and instruction of Site Engineer.	Sqm			

Bus



[Signature]

कमल राज उपाध्याय
प्रमुख प्रशासकीय अधिकृत

LIGHTING MAST SHAFT & ACCESSORIES PART

15	Supply of 16Mtr high mast polygonal with 20 sides Hop dip galvanized 65-85 micron having Top DIA-150 mm, Bottom DIA - 460mm in 2 section , (length- 8300 mm each) Sheet thickness Bottom Section- 4 mm, Top Section 3 mm. BASE PLATE DIA- 670 mm x 30 mm PCD 570 mm with following items: HIGT Mast SECTIONS with base plate,Lantern carriage suitable to fix upto 8 nos of LED luminaries symmetrically on 08 Arms. 3 Point suspension Head frame, L-stopper(3 nos) Mounting plates Lightening Arrestor and etc . FOUNDATION BOLT-M30 X 850 (08 Nos.) with Template and Anchor Plate MTR LIGHTENING MAST ACCESSORIES PART: Double Drum Winch 500kg (Gear Ratio-53:1 Motor 1.5 HP,SS Wire Rope (Grade AISI 316, Manual Operation Handle,Trailing Cable(1set 5 crore X 4 sq.mm EPR PCP Round Copper). Make: Crompton,Wipro,Philips,Osram & Trilux or Equivalent.	SET			
16	Supply of 12.5Mtr high mast polygonal with 20 sides Hop dip galvanized 65-85 micron having Top DIA-150 mm, Bottom DIA - 360mm in 2 section , (length- 6300 mm each) Sheet thickness Bottom Section- 4 mm, Top Section 3 mm. BASE PLATE DIA- 270 mm x 25 mm PCD 570 mm with following items: HIGT Mast SECTIONS with base plate,Lantern carriage suitable to fix upto 8 nos of LED luminaries symmetrically on 08 Arms. 3 Point suspension Head frame, L-stopper(3 nos) Mounting plates Lightening Arrestor and etc . FOUNDATION BOLT-M30 X 650 (06 Nos.) with Template and Anchor Plate 12.5 MTR LIGHTENING MAST ACCESSORIES PART: Double Drum Winch 500kg (Gear Ratio-53:1 Motor 1.5 HP,SS Wire Rope (Grade AISI 316, Manual Operation Handle,Trailing Cable(1set 5 crore X 4 sq.mm EPR PCP Round Copper). Make: Crompton,Wipro,Philips,Osram & Trilux or Equivalent.	SET			

Bus



कमल राज उपाध्याय
प्रमुख प्रशासकीय अधिकृत

17	Supplying, fitting and fixing 400watt integral LED Flood light Luminaries, comprises of elegantly designed highly efficient, pressure die-cast aluminum housing with fins for better heat dissipation and heat resistant and Lumen(>115Lm/watt)and Poly Carbonate Lence with toughened glass cover, operation voltage range 100-300 Volt AC Color temperature is 5700K, 60 degree Narrow LED beam angle, External SPD-10KV. IP-66 protection fitting Bearing with Wipro Cat. Ref. LF20-502-060-57-XX, ISO certified model No. LFLPI-400-CDL, make : Crompton, Wipro, Philips Osarm & Trilux or Equivalent.	SET			
18	Supplying, fitting and fixing 200watt integral LED Flood light Luminaries, comprises of elegantly designed highly efficient, pressure die-cast aluminum housing with fins for better heat dissipation and heat resistant and Lumen(>115Lm/watt)and Poly Carbonate Lence with toughened glass cover, operation voltage range 100-300 Volt AC Color temperature is 5700K, 60 degree Narrow LED beam angle, External SPD-10KV. IP-66 protection fitting Bearing with Wipro Cat. Ref. LF20-502-060-57-XX, ISO certified model No. LFLPI-400-CDL, make : Crompton, Wipro, Philips Osarm & Trilux or Equivalent.	SET			
19	Supplying and fixing of 2 nos earthing 3 mtr long with GI PIPE, 25X3 mm GI Strip,nut-bolt & washers etc. complete.	SET			
20	Supply and fixing of Outdoor Feeder Pillar housing comprising of suitable of 50 Amp .MCCB,25Amp.Contractor, Astro timer switch for automatic ON/OFF of lights Energy Meter etc.complete	SET			
21	Erection, Commissioning & Supervision of above High AC Lighting System including wiring & fixing of Luminaire with Fellable Pipe wiring with 2.5 sqmm 3 core & modern engineering practices as per instruction of site engineer.	SET			
22	Twin dome LED Aviation light etc.complete.	SET			
23	50mm GI Pipe with 2 pair clamp , nut -bolt and washers	SET			

Bus



[Signature]

कमल राज उपाध्याय
प्रमुख प्रशासकीय अधिकृत