बेलौरी नगरपालिका
नगर कार्यपालिकाको कार्यालय
बेलौरी कंचनपुर
सुदुरपश्चिम प्रदेश , नेपाल
स्थापित २०७३

पत्र सं :२०८३/०८४ मिति : २०८३/०८/०४

च.नं ४०४

विषय : दररेट पेश गर्ने सम्बन्धी ७ दिने सुचना ।

श्री सरोकारवाला फर्महरु सबै ।

प्रस्तुत सम्बन्धमा चालु आ व २०८३।०८४ मा यस कार्यालयलाई तपसिलका समान आवश्यक भएको र सोको लागि लागत अनुमान तयार गर्ने प्रयोजनार्थ देहायको स्पेसिफिकेसन का आधारमा ७ दिन भित्र भ्याट बाहेक आफनो दररेट पेश गर्न हुन अनुरोध छ ।

तपसिल

Fire Extinguisher ABC

- CYLINDER MATERIAL: M.S.
- FIRE RATING: 3A 89B
- EXTINGUISHING MEDIUM: POWDER
- TEMPERATURE RANGE: -30°C to +60°C
- DISCHARGE TIME: MORE THAN 13 S
- DISCHARGE RANGE: MORE THAN 02 M
- OPERATING PRESSURE: 15 BAR
- TEST PRESSURE: 35 BAR
- PRESSURERE GAUGE SHOULD PROVIDE AT HEAD
- EXCELLENT: NITROGEN

S.N.	Description of Items	Qty
1	Fire Extinguisher ABC CAPACITY (KG): 1	1 pic
2	Fire Extinguisher ABC CAPACITY (KG): 4	1 pic
3	Fire Extinguisher ABC CAPACITY (KG): 6	1 pic
4	Fire Extinguisher ABC CAPACITY (KG): 9	1 pic

२८।२।८४

खेमराज जोशी
प्रमुख प्रशासकीय अधिकृत